



Outlet Identification

- 1 2" Liquid fill valve w/ 1 1/2" connection
- 2 1 1/2" Vapor balance valve w/ 1" connection
- 3 1" Vapor to process
- 4 1 1/2" Liquid CO2 from tank
- 5 2" Liquid CO2 from tank (Capped)
- 6 1/2" High pressure to gauges
- 7 1/2" Gauge line purge valve
- 8 1/2" Low pressure to gauges
- 9 2" Vaporizer return (Capped)
- 10 1/2" Isolating valve for bleeder
- 11 1/4" Bleed valve set at 335 PSI
- 12 A-G 3/4" safety relief valves
- 13 3/4" Henry Safety Isolation valve
- 14 2" Vapor to plant (Capped)
- 15 1/2" Liquid filling blowdown valve
- 16 1/2" Vapor balance blowdown valve
- 17 Refrigeration unit
- 18 Refrigeration coils
- 19 Insulation
- 20 Thermostatic expansion valve
- 21 Manway access
- 22 2" Vapor to plant (Capped)
- 23 Refrigeration unit control panel

NO.	DESCRIPTION	DATE
REVISIONS		

Carbo Tech, Inc.
EQUIPMENT

P.O. Box 1838 -- Monroes, Georgia 30855

6 Ton
Carbon Dioxide Storage Unit
Outlets and Controls Location

DRN BY: J.W.W. SCALE: None
CKD BY: DATE: 4.08.02

CAR-789-25