



**NOTES:**

- 1) All piping to be Sch. 80 A-106 seamless, fittings to be 2000# F.S.
- 2) Valves to be Apollo 76 series.
- 3) Safety relief set at 450 PSIG.

|         |       |       |       |
|---------|-------|-------|-------|
| CT-28KW | 4'-3" | 2'-0" | 4'-8" |
| CT-18KW | 4'-9" | 2'-0" | 4'-3" |
| CT-9KW  | 4'-9" | 2'-0" | 4'-3" |
| MODEL   | A     | B     | C     |

**DIMENSIONS**

| NO. | DESCRIPTION    | DATE    |
|-----|----------------|---------|
| 2   | Changed Valves | 3-23-83 |
| 1   | Jacket         |         |

**CARBO TECH, Inc.**  
 P.O. Box 652 --- Shellville, Georgia 30278

*Carbon Dioxide Vaporizer  
 Electric Pressure Build*

DRN BY: J.W.W.      SCALE: NONE  
 CKD BY:              DATE: 8/24/87  
 VAP-003-21